

## 2015 Virginia Electrical Code (2014 NEC)

- NEC Code Wide Change – Voltage Increase
- NEC Art. 100 Definitions – Selective Coordination
- NEC Art. 100 Definitions – Intersystem Bonding Termination
- NEC Art. 100 Definitions – Separately Derived System
- NEC 110.16 – Arc Flash Hazard Warnings
- NEC 110.21(B) - Field Applied Hazard Markings
- NEC Code Wide Change – Lockable Disconnecting Means
- NEC 110.26 E(2)(a)&(b) Outdoor Installations
- Outdoor Dedicated Space
- NEC 200.4(B) – Neutral Conductor Grouping In Enclosures
- NEC 210.8(A)(7) & IRC E3902.7 – GFCI at Sinks
- NEC 210.8(A)(9)& IRC E3902.8 – GFCI Tubs and Showers
- NEC 210.8 (A)(10)& IRC E3902.9 – GFCI laundry Areas
- NEC 210.8(B)(8) – GFCI Garages
- NEC Art. 210.8 (D) – Dishwashers
- NEC 210.12 & IRC E3902.16 – AFCI Protection
- NEC 210.12(C) – AFCI Protection in Dormitories
- NEC 210.13 – Ground Fault Protection of Equipment
- NEC 210.17 & IRC E3702.13 – Electric Vehicle Branch Circuit
- NEC 210.52(E) 1,2,3 & E3901.7 – Outdoor Outlets
- NEC 210.52 (G)(1) & IRC E3901.9 – Garage Receptacles
- NEC 210.64 – Electrical Service Areas
- NEC 220.12 – Lighting Loads
- NEC 240.21(B)(1) Exception – Minimum Conductor Size
- NEC 250.64 (B) – Grounding Electrode
- NEC 250.66 (A) & (B) – Electrode Conductor Sizing
- NEC 250.68 (C)(3) – Grounding Electrode Connections
- NEC 250.102(C) – Bonding Conductors and Jumpers
- NEC 250.122 (B) – Size of Equipment Grounding Conductors
- NEC 300.22 (C)(1) – Wiring Methods
- NEC 300.38 – Raceways in Wet Locations Above Grade
- NEC 310.15(B)(7) & IRC E3603.1.1 - Service Entrance Conductors and Main Feeder Sizing
- NEC 314.15 – Damp & Wet Locations
- NEC 393 – Low Voltage Suspended Ceilings
- NEC 404.2 (C) & IRC E4001.15 – Neutral Conductors on Light Switches
- NEC 406.3 (E) – Controlled Receptacle Marking

- NEC 406.5 (E) – Receptacles in Counter Tops and Similar Areas
- NEC 406.9(B)(1) & IRC E4002.9 – Extra Duty Hoods
- NEC 406.15 & IRC 4002.15 – Dimmer Controlled Receptacles
- NEC 408.4 (B) – Supply Source Identification
- NEC 408.4 (B) – Retrofit Kits
- NEC 410.10 (F) - Luminaires Under Roof Decking in Exposed or Concealed Locations
- NEC 422.5 – Readily Accessible GFCI Devices
- NEC 422 – GFCI Protection
- NEC 422.49 – High Pressure Spray Washers
- NEC 422.51 (B) – GFCI on Hardwired Vending Machines
- NEC 424.66 (A)&(B) – Duct Heaters
- NEC 445 – Generators
- NEC 450 – Transformers
- NEC 501.40 – Multi-Wire Branch Circuits
- NEC 516 – Revised Title
- NEC 517.2 – Definitions
- NEC 517.18 (A) – Patient Bed Location – Receptacle Identification
- NEC 517.18 (B) – General Care Patient Bed Location – Number of Receptacles
- NEC 517.19 (B) – Critical Care Patient Bed Location – Number of Receptacles
- NEC 517.19 (C) – Operating Room – Number of Receptacles
- NEC 517.30 (B) – Separate Branches
- NEC 517.41 (E) –Essential Branch Receptacles
- NEC 600.6 (A) (1) – Sign Enclosure Disconnecting Means
- NEC 646 New Article – Modular Data Centers
- NEC 680.2 & IRC4201.2 – Storable/Portable Spas and Hot Tubs
- NEC 680.12 – Fountain Disconnect
- NEC 680.21 (C) – GFCI for Pool and Spa Motors
- NEC 680.22 (A) (1) – Required Receptacles for Pools
- NEC 680.22 (B) (6) & IRC E4203.4.3 – Low Voltage Luminaires
- NEC 680.42 (B) – Bonding Requirements/Exceptions
- NEC New 700.8 – Surge Protection
- NEC 700.19 – Emergency Lighting and Power Circuits
- NEC 728 New Article – Fire Resistant Cable Systems
- NEC 750 New Article – Energy Management Systems

